

FIRE SAFETY CERTIFICATE**ONLINE UID No.**UPFS/2026/220432/LLP/LALITPUR/522/CFO**Dated:** 30-09-2026

Certified that the **PRATIBHASTHALI GYANODAYA VIDYAPEETH**(name of the building or premises) at **land no. 198 1, 198 8, 201 1, 201 5, GRAM MASORA KHURD LALITPUR** comprised of **NIL** basement(s) and **(Ground + 3 Floors)** (upper floors) owned/ occupied by **PRATIBHASTHALI GYANODAYA VIDYAPEETH**(name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of *UP Fire Service Act/Rules* Fire Service Rules, and verified by the officers concerned of Fire Service on **30/09/2026** (date of inspection) in the presence of **RICHA JAIN BEHALF OF SUSHMA JAIN , PRATIBHASTHALI GYANODAYA VIDYAPEETH, MASORA KHURD, LALITPUR** (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes **XII (X/ XII)** With effect from **30/09/2026** TO **29/09/2031** for a period of **05 (FIVE)** year in accordance with rule and subject to compliance of specific conditions as appended:-

1. **All fire extinguishers must be maintained and refilled before the expiry date.**
2. **Emergency exit routes and staircases must remain completely free from any obstruction.**
3. **Fire mock drills must be conducted for students and staff at least twice a year.**
4. **First-aid hose reels and water storage tanks must be kept operational at all times.**

Issued on 30/09/2026 (date of issue) at LALITPUR (place) by

• Signature with Seal:


मुख्य अग्निशमन अधिकारी
ललितपुर

- **Name:** SHRI TABARAK HUSSAIN
- **Designation:** CHIEF FIRE OFFICER LALITPUR
- **Name & Address of Department/ Office:** LALITPUR

To,

PRATIBHASTHALI GYANODAYA VIDYAPEETH

MASORA KHURD,

LALITPUR (U.P.)

(Name & Address of the Institution)